



## ADDENDUM 1

Country : MYANMAR  
 Project : Ayeyarwady Integrated River Basin Management (AIRBM) Project  
 Credit No. : IDA 55590  
 Contract Title : PMU Building  
 Reference No : CW1.1.1  
 Date of issue of Addendum 1: 14 Sept 2017



This Addendum 1 is to inform the prospective bidders of the amendments made to the Bidding Document for **CW1.1.1 –PMU Building** as per Bidding Document for the works for PMU Building.

**1. Section 4 - Technical Specifications and Drawings, Clause 32. Water Supply System: Pump Connection, Domestic Ground Tank & Septic Tank c/w valves, pipe connections and all necessary materials.**


Following sentence is added to the end of Clause 32. Water Supply System: Pump Connection, Domestic Ground Tank & Septic Tank c/w valves, pipe connections and all necessary materials.

*“Location of pump house shall be between ground tank and proposed building. Dimension should be enough to cover the pump from weather. The shop drawing for the pump house will be prepared by the Contractor.”*

**2. Section 4 – Technical Specifications and Drawings, Architectural Drawing, Drawing No. 44: DWIR-3STY-PMU-PS01 , For Shera Board Partition, 3”x2” M.S frame should be amend as follow;**

Original	Amendment
 <p style="text-align: center;">3" x 2" M.S Frame Shera Board Shera Board</p>	 <p style="text-align: center;">3" x 2" M.S Frame 75 mm x 50 mm aluminium frame Shera Board Shera Board</p> <p style="text-align: right;">See Floor Detail Drawin</p>
	<p>3”x2” M.S Frame to be deleted and 75mmx50mm aluminium frame is replacing on it.</p>

Sincerely,

  
 14-9-2017

**Aung Myo Khaing (Mr.), Component 3 Director**  
**On behalf of Project Director**  
**Project Management Unit (PMU)**  
**Ayeyar wady Integrated River Basin Management (AIRBM) Project**